

CITY OF NEWTON, MASSACHUSETTS

PURCHASING DEPARTMENT

purchasing@newtonma.gov

Fax (617) 796-1227

December 19, 2011

ADDENDUM #3

INVITATION FOR BID #12-32

LOWER FALLS COMMUNITY CENTER IMPROVEMENTS

THIS ADDENDUM IS TO: **Answer the following Questions:**

Q1. Drawing - D2 - Scale on D2 is 1/8"=1'-0" and not 1/4"=1'-0".

A1. See Addendum No. 1, Item 1.05 on page 3.

Q2. Drawing A5 – Details 5 - This details applies to walls sections 3/A4 and 5/A4 too, not only 1/A4?
Please confirm.

A2. Detail 5/A5 refers to wall sections 1/A4 & 3/A4. Does not apply to wall section 5/A4.

Q3. Request for Clarification - Question from window supplier is 1/4" glass required in windows?
Suggests 1/8" standard or possible 3/16", possible 1/4" at gym interior.

A3. Yes. Refer to Specification Section 08 54 13 “Fiberglass Windows”, Sub-Section 2.05 “Glass and Glazing”.

All other terms and conditions of this bid remain unchanged.

PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM.

Thank you.



Rositha Durham

Chief Procurement Officer